



# Compliance Statement

No. 2017-610

## Screened Channel, Class E<sub>A</sub>

### Company

Turera Teknolojik Ürünler A.Ş.  
Küçükbakkalköy Mah. Ozan Veysel Sk. No:9 K:1 D:2  
Ataşehir İstanbul  
Turkey

### Channel Identification (4 connector model)

#### Horizontal Cable:

Zemecs T136ZMXY Cat6A SSTP 23AWG LSZH LAN Cable  
(M denotes jacket color, x denotes length, and Y denotes package type)

#### Cords:

Zemecs T234ZXY Cat6A SSTP 26AWG LSZH Patch Cord  
(X denotes jacket color and Y denotes length)

#### Wall Outlet:

Zemecs T434C21B, Zemecs T432A12B, Zemecs T432D12B

#### Patch Panel:

Zemecs T334A22B, Zemecs T372A22B

### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-T731098, DANAK-19/18119

### EC Cabling product ID

5903

### CS valid until

20 July 2018

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 20 July 2017

Lars Lindskov Pedersen  
Test Manager

Dennis Andersen  
Head of Department

### DELTA – a part of FORCE Technology

Venlighedsvej 4      Tel. +45 72 19 40 00  
2970 Hørsholm      Fax +45 72 19 40 01  
Denmark      www.madebydelta.com/cable

